


## BATHROOM ZONES



**ZONE 0** - Inside the bath or shower.

Any fitting used here must be SELV (max. 12V) and a minimum of IP-7 (protected against immersion).

**ZONE 1** - Above the bath or shower to a height of 2.25m.

An IP rating of at least IP-5

**ZONE 2** - The area 0.6m outside of zone 1

An IP rating of at least IP-4 (see Note 1)

**Out of Zone** - Anywhere outside Zones 0,1 & 2.

No special protection required (see Note 1)

Notes:

1. If there is a likelihood of water jets being used for cleaning purposes, a minimum of IP-5 is required.
2. This information is provided for guidance. Refer to the current IEE regulations for the latest information.